

**ITB # 5242024 ISU Softball Field Turf Install at Miller Ranch Stadium**  
**ATTACHMENT 4 -VENDOR QUESTIONS**

PLEASE DO NOT IDENTIFY YOUR NAME OR YOUR COMPANY'S NAME OR PRODUCT NAMES OF INTELLECTUAL PROPERTY IN YOUR QUESTIONS.

ADD ROWS BY HITTING THE TAB KEY WHILE WITHIN THE TABLE AND WITHIN THE FINAL ROW.

The following instructions must be followed when submitting questions using the question format on the following page.

1. DO NOT CHANGE THE FORMAT OR FONT. Do not bold your questions or change the color of the font.
2. Enter the ITB section number that the question is for in the "ITB Section" field (column 2). If the question is a general question not related to a specific ITB section, enter "General" in column 2. If the question is in regards to a University Term or Condition or a Special Term or Condition, state the clause number in column 2. If the question is in regard to an attachment, enter the attachment identifier (example "Attachment 1") in the "ITB Section" (column 2).
3. Do not enter text in the "Response" field (column 4). This is for the University's use only.
4. Once completed, this form is to be e-mailed to the ITB Lead listed on the ITB Administrative Page. The e-mail subject line is to state the ITB number followed by "Questions."

**ITB5242024**

**Addendum 1**

**Attachment 4 Answers To Questions**

ITB #52420242024 ISU Softball Field Turf Install at Miller Ranch Stadium

	ITB Section	Question	Response
1	3.3.3	It states 3.5" of the 3/8" compacted permeable washed rock (finishing stone). Is this supposed to be 1.5" in lieu of 3.5"? We do not recommend installing the finishing rock at the 3.5" depth.	Overall depth of washed rock to be 8-inches overall. How the washed rock is layered will be to manufacturers/installers best installation methods, recommendations and warranty. Provide a submittal to ISU of manufacturer recommended installation prior to installation. ISU will not accept less than 8" field verified rock base.
2	3.9.1.2	Are there any minimum turf specs? One that describes the turf system, face weight, pile height, yarn type, etc.?	We don't have any minimum technical turf specs. However, we want turf specs comparable to other turf softball fields around the area or around the country with similar type of climate environment.
3	3.9.1.3	Are the baseball bases just at 90 feet?	The softball field bases are 60 feet.
4	3.9.1.4	Are renders for the donor field name?	"DIRECT COMMUNICATIONS FIELD" in a generic font and in one color down the right field line and the left field line. Please see Attachment 7
5	3.9.1.5	Are there any renders for the institute logo?	Please see Attachment 7 Miller Ranch Logo Rendering. Can contractor

	ITB Section	Question	Response
			provide the largest sizing in ratio of the turf and filed layout? (see also <b><u>Section 3.1.4 Design Services.</u></b> Owner to sign off final rendering provided by contractor.
6	3.9.1.6	What is the size and location of all logos?	Please see Attachment 7 Miller Ranch Logo Rendering. Can contractor provide the largest sizing in ratio of the turf and filed layout? (see also <b><u>Section 3.1.4 Design Services.</u></b> Owner to sign off final rendering provided by contractor.
7	3.9.1.7	How many replacement panels each area?	Maybe one or two replacement panels for each area.
8	3.9	Is there a shock pad?	The shock pad is to be provided as an ALTERNATIVE price for owner review and acceptance. (see Section 3.12.2 <b><u>Alternates</u></b> )
9	3.9	Is there specifications on infill materials? What type?	We would like the manufacturers/installers best installation methods, recommendations and warranty.
10	3.9	Sand and SBR rubber?	We would like the manufacturers/installers best installation methods, recommendations and

	ITB Section	Question	Response
			warranty for our climate environment.
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			